



City of Payne Springs
19601 CR 2529
Payne Springs, TX 75156
903-451-9229

TEMPORARY SERVICE POLE SPECIFICATIONS

1. The electric service for all temporary construction shall be equipped with a rain-tight enclosure, dual element fuses or circuit breakers. (NO PLUG TYPE FUSES ALLOWED.) (1) The minimum setting depth may be reduced to three feet with 2x4 min. bracing mounted at 2/3 height of the point of attachment, secured with 2x4 min. stakes, and cross-braced with a 2x4 min. brace. (2) For temporary construction only a 4x4x16 un-spliced treated pole may be substituted for the 6 inch minimum penta-treated or equivalent round pole. (3) For temporary construction ONLY, the conductors used in 100 amp service shall be no smaller than #6 THHN or #4 THW cu.
2. Receptacles used on temporary service poles shall be installed in a rain-tight box.
3. Temporary service poles shall have a rain-tight disconnecting device sufficient for voltage employed and for the current, which must be interrupted.