



121 N. Arroyo Blvd. // P.O. Box 389  
Rio Hondo, Texas 78583-0389  
Office: (956) 748-2102 Fax: (956) 748-4394

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. [These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.]

The CITY OF RIO HONDO, PWS ID TX0310006, failed to meet the minimum treatment technique requirements for the month of JAN 2025, NOV 2022, APR 2022. Specifically, our water system had:

- **More than 5% of the combined filter effluent turbidity readings were above 0.3 NTU for the month. (44)**

The CITY OF RIO HONDO, PWS ID TX0310006, failed to meet the minimum treatment technique requirements for the month of JAN 2025. Specifically, our water system had:

- **combined filter effluent turbidity readings above 1.0 NTU for the month. (43)**

**What is being done?**

The City of Rio Hondo has taken the following corrective actions to prevent a recurrence of the violations: The operators have been instructed to keep a closer look at the chemical dosage and adjust as needed.

*Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

If you have questions regarding this matter, you may contact:

Water System Official: Murl Kemmerling

Area code + phone number: (956) 748-2102

Posted / Delivered on: 4-9-2025