

## **Sanitary Sewer Incident Report**

Traditions of Braselton Force Main Break.

Jefferson, GA, 30549

Dates: May 9<sup>th</sup> to May 13<sup>th</sup>

1. The Force main running through the Traditions subdivision was ruptured and created a large spill, JCWSA staff after searching found the break and immediately acted. The break was in a heavily wooded area and hidden by trees and brush.
2. Approximately 420,000 gallons have been spilled estimated by lift station run times. This is classified as a major spill.
3. JCWSA staff, with the assistance of a local contractor, have repaired the break and completed cleanup efforts at this location.
4. The Georgia EPD has been notified and is aware of the incident.
5. The Health Department has been notified and is aware of the incident.

If you have any questions, please call 706-367-1741 EXT 302